Research Article

An Efficient Algorithm for Transient Calculation of the Electric Networks Including Magnetizing Branches

Xiaoqing Zhang

School of Electrical Engineering, Beijing Jiaotong University, Beijing 100044, China

Correspondence should be addressed to Xiaoqing Zhang, zxqiong@hotmail.com

Received 30 July 2010; Revised 22 January 2011; Accepted 10 March 2011

Academic Editor: Yuri Vladimirovich Mikhlin

Copyright © 2011 Xiaoqing Zhang. This is an open access article distributed under the Creative Commons Attribution License, which permits unrestricted use, distribution, and reproduction in any medium, provided the original work is properly cited.

A simplified model of magnetic saturation characteristics is proposed in this paper for transient calculation of the electric networks including magnetizing branches. The model represents the magnetic saturation characteristics by the continuous function instead of the piecewise linear approximation. Based on the proposed model, an efficient transient algorithm is developed. The nonlinear differential equations describing the transient behavior of the magnetizing branches are solved by the semiexplicit Runge-Kutta method, in which noniterative computations are involved. The transient calculation for the remaining linear network is performed in terms of the solution to the magnetizing branches. A comparison is made between calculated and experimental results to confirm the validity of the algorithm.

1. Introduction

Electric power systems contain a series of ferromagnetic components, such as power transformers, potential transformers, and shunt reactors. Owing to the presence of the ironcores, the ferromagnetic components have nonlinear magnetizing characteristics. When a switching or fault operation occurs in the vicinity of the ferromagnetic components, their magnetic saturation characteristics may exert a significant influence on the transient phenomena. In such a situation, it is necessary to take account of the magnetic saturation characteristics in transient calculation. The magnetic saturation characteristics are usually described by the flux linkage-magnetizing current curves, namely, the saturation curves. The piecewise linear approach has been widely employed for simulating the saturation curves in the transient solution of magnetizing branches [1–5]. In fact, this approach can only give a roughly approximate treatment to the nonlinearity of the saturation curves. When a saturation curve is approximated in

Figure 1: Circuit representation of magnetizing branch.

piecewise linear form, some illegal overshoot conditions are frequently caused at the turning points of piecewise linear inductances, which may give rise to a numerical error for the transient calculation [4]. The compensation method has also been used to solve the transient phenomena associating with nonlinear elements [4, 5]. However, it leads to an increase in computational burden due to its iterative solution. In view of these drawbacks, this paper proposes a simplified model of magnetic saturation characteristics for transient solution of magnetizing branches. The saturation curves are represented by the continuous function instead of the piecewise linearization. On the basis of the model, an efficient algorithm is developed for transient calculation. In the algorithm, the electric network is divided into two parts, that is, the magnetizing branches and the remaining linear network. The nonlinear differential equations are formed for describing the transient behavior of the magnetizing branches. The semiexplicit Runge-Kutta method is used to numerically solve these equations, which can avoid the iterative computations. The transient calculation for the remaining linear network can be performed subsequent to the solution to the magnetizing branches. In order to confirm the validity of the algorithm, the calculated results are compared with the experimental ones.

2. Modeling of Magnetizing Branches

From the point of view of the practical application in transient calculation, a magnetizing branch can be simplified as a nonlinear inductance in parallel with an appropriate core loss resistance R_m [6–9], as shown in Figure 1. The constant resistance R_m can be determined from the manufacturer's data on the core loss of ferromagnetic components versus applied voltage [8, 9]. The nonlinear inductance is characterized by the saturation curve, as shown in Figure 2. In this study, the saturation curve is formulated as

$$\lambda = Ai + B \tan^{-1} \frac{i}{W}, \quad (2.1)$$

where λ is flux linkage, i is magnetizing current, and A, B, W are the constants which can be determined from the corresponding measured data by using the least squares curve fitting method. The dynamic inductance necessary to transient calculation can be derived from (2.1)

$$L_d = \frac{d\lambda}{di} = A + \frac{BW}{W^2 + i^2}. \quad (2.2)$$

Figure 2: Saturation curve.

Figure 3: An electric network including N magnetizing branches.

In the unsaturation region, the small magnetizing current yields a large linear inductance

$$L_{d0} \approx A + \frac{B}{W}. \quad (2.3)$$

In the saturation region, the magnetizing current becomes large and the dynamic inductance is reduced to

$$L_{ds} \approx A. \quad (2.4)$$

It is clear from (2.3) and (2.4) that (2.1) can give a reasonable description to the nonlinear saturation behavior of practical ferromagnetic components, such as power transformers and potential transformers.

3. Algorithm for Transient Calculation

An electric network including N magnetizing branches is depicted in Figure 3, where the N core loss resistances (R_m) have been incorporated into the linear network. Let λ and i denote the flux linkage and magnetizing current vectors, respectively, that is, $\lambda = [\lambda_1, \lambda_2, \dots, \lambda_N]^T$ and $i = [i_1, i_2, \dots, i_N]^T$. In order to obtain the solution to the N nonlinear inductances,

Figure 4: Thevenin equivalent procedure.

Figure 5: Thevenin equivalent network expressed in matrix form.

a Thevenin equivalent procedure is made for Figure 3 [1, 4]. By removing the N nonlinear inductances from Figure 3, the open-circuit voltage vector $\mathbf{u}_0$ ($\mathbf{u}_0 = [u_{10}, u_{20}, \dots, u_{N0}]^T$) and input impedance matrix $\mathbf{Z}_0$ ($N \times N$) associated with the N ports can be conveniently calculated by the method given in [4, 5], as shown in Figure 4. After obtaining $\mathbf{u}_0$ and $\mathbf{Z}_0$, Figure 3 is simplified as a Thevenin equivalent network expressed in matrix form, as shown in Figure 5. The matrix differential equation can be given for the N nonlinear inductances

$$\frac{d\lambda}{dt} = \mathbf{u}_0 - \mathbf{Z}_0 \mathbf{i}. \quad (3.1)$$

The above derivative can be changed into

$$\frac{d\lambda}{dt} = \frac{d\lambda}{di} \frac{di}{dt} = \mathbf{L}_d(\mathbf{i}) \frac{d\mathbf{i}}{dt}. \quad (3.2)$$

The nonlinear dynamic inductance matrix $\mathbf{L}_d(\mathbf{i})$ is given as

$$\mathbf{L}_d(\mathbf{i}) = \text{diag} \left[\frac{d\lambda_1}{di_1}, \frac{d\lambda_2}{di_2}, \dots, \frac{d\lambda_N}{di_N} \right], \quad (3.3)$$

where diag denotes the diagonal matrix and the N nonlinear inductances are considered to be uncoupling for the real reason. Each diagonal element of the matrix $\mathbf{L}_d(\mathbf{i})$ can be determined by (2.2). Substituting (3.2) into (3.1) leads to

$$\frac{d\mathbf{i}}{dt} = \mathbf{L}_d^{-1}(\mathbf{i})(\mathbf{u}_0 - \mathbf{Z}_0\mathbf{i}). \quad (3.4)$$

Letting $\mathbf{F}(\mathbf{i}) = \mathbf{L}_d^{-1}(\mathbf{i})(\mathbf{u}_0 - \mathbf{Z}_0\mathbf{i})$, this can be rewritten in a simplified form

$$\frac{d\mathbf{i}}{dt} = \mathbf{F}(\mathbf{i}). \quad (3.5)$$

Equation (3.5) represents N nonlinear differential equations and may be a system of stiff differential equations when modeling the real data of the electric networks. This kind of problem is apparent in numerical solution of power transformer transients. The stiffness of differential equations makes it difficult for the explicit difference scheme to solve these equations successfully. The explicit difference scheme, applied to stiff differential equations, is numerically unstable because this difference scheme results in an increase of truncation error [10]. The implicit difference scheme, although numerically stable, does increase the solution time for the magnetizing branches due to its incorporating of the iterative computations into the numerical solution process. Obviously, a suitable solving technique for (3.5) should be numerically stable and avoid the iterative computations. The semiexplicit Runge-Kutta method can accomplish this purpose. A generalized semiexplicit Runge-Kutta difference scheme is given as follows [11]:

$$\begin{aligned} \mathbf{i}_{n+1} &= \mathbf{i}_n + k_1\mathbf{H}_1 + k_2\mathbf{H}_2 + \dots \\ \mathbf{H}_1 &= \Delta t[\mathbf{F}(\mathbf{i}_n) + a_1\mathbf{A}(\mathbf{i}_n)\mathbf{H}_1] \\ \mathbf{H}_2 &= \Delta t[\mathbf{F}(\mathbf{i}_n + b_1\mathbf{H}_1) + a_2\mathbf{A}(\mathbf{i}_n + c_1\mathbf{H}_1)\mathbf{H}_2] \\ &\vdots \quad \quad \quad \vdots, \end{aligned} \quad (3.6)$$

where $\mathbf{A}$ is the Jacobian matrix, $\mathbf{A}(\mathbf{i}) = \partial\mathbf{F}(\mathbf{i})/\partial\mathbf{i}$. Through a quite tedious calculation, it is possible to expand $\mathbf{i}_{n+1} - \mathbf{i}_n$ in (3.6) as a power series in Δt and compare this with the Taylor's series. The detail was given in [12]. In order to ensure the correspondence between the early

Figure 6: Completely linear network.

terms of both the series, the following relationships should be satisfied for a truncation error $O[(\Delta t)^4]$:

$$\begin{aligned}
 \Delta t : k_1 + k_2 - 1 &= 0 \\
 (\Delta t)^2 : k_1 a_1 + k_2 (a_2 + b_1) - \frac{1}{2} &= 0 \\
 (\Delta t)^3 : \begin{cases} k_1 a_1^2 + k_2 [a_2^2 + (a_1 + a_2)b_1] - \frac{1}{6} = 0 \\ k_2 \left(a_2 c_1 + \frac{1}{2} b_1^2 \right) - \frac{1}{6} = 0. \end{cases} & \quad (3.7)
 \end{aligned}$$

These relationships involve six adjustable constants, k_1 , k_2 , a_1 , a_2 , b_1 , and c_1 . Choosing the first two constants $k_1 = 0.75$ and $k_2 = 0.25$ [13], the remaining four constants can be determined as

$$\begin{aligned}
 a_1 = a_2 &= \frac{1}{2} \left(1 + \sqrt{\frac{1}{3}} \right) = 0.788675134595 \\
 b_1 &= -\frac{2}{\sqrt{3}} = -1.15470053838 \\
 c_1 &= 0.
 \end{aligned} \quad (3.8)$$

Thus, (3.6) is simplified as a two-stage and third-order difference scheme

$$\begin{aligned}
 \mathbf{i}_{n+1} &= \mathbf{i}_n + 0.75\mathbf{H}_1 + 0.25\mathbf{H}_2, \\
 \mathbf{H}_1 &= \Delta t [\mathbf{1} - 0.788675134595\Delta t\mathbf{A}(\mathbf{i}_n)]^{-1} \mathbf{F}(\mathbf{i}_n), \\
 \mathbf{H}_2 &= \Delta t [\mathbf{1} - 0.788675134595\Delta t\mathbf{A}(\mathbf{i}_n)]^{-1} \mathbf{F}(\mathbf{i}_n - 1.15470053838\mathbf{H}_1),
 \end{aligned} \quad (3.9)$$

where $\mathbf{1}$ is unit matrix. Once the magnetizing current vector $\mathbf{i}$ is obtained by using the difference formula (3.9) to solve (3.5), the transient calculation of the linear network in Figure 3

Figure 7: An electric network containing two groups of magnetizing branches.

Figure 8: Single phase network taking matrix form.

can be performed easily. By replacing the N nonlinear inductances with the N current sources equal to the N known elements of the magnetizing current vector $\mathbf{i}$, as shown in Figure 6, Figure 3 is changed into a completely linear network. The transient responses can be calculated for the linear network by using the algorithm presented in [1, 4, 5].

4. Case Study

An electric network with two groups of magnetizing branches at both ends of transmission lines is shown in Figure 7, where the group at the sending end corresponds to a transformer and the other at the receiving end corresponds to a reactor. The core loss resistance of the reactor is ignored [14]. The network data are given in the following:

$$\begin{aligned}
 \mathbf{e}(t) &= [1.0 \cos(\omega t + 180^\circ), 1.0 \cos(\omega t + 60^\circ), 1.0 \cos(\omega t - 60^\circ)]^T \text{ p.u.} \\
 \mathbf{Z}_c &= \text{diag}[606.87, 279.88, 279.88] \Omega, \quad \boldsymbol{\tau} = [1.43 \times 10^{-3}, 1.01 \times 10^{-3}, 1.01 \times 10^{-3}]^T \text{ s}, \\
 l &= 305 \text{ km}, \quad \mathbf{L} = \begin{bmatrix} 0.592 & -0.149 & -0.149 \\ -0.149 & 0.592 & -0.149 \\ -0.149 & -0.149 & 0.592 \end{bmatrix} \text{ H}, \quad \mathbf{R} = \begin{bmatrix} 13.08 & -3.27 & -3.27 \\ -3.27 & 13.08 & -3.27 \\ -3.27 & -3.27 & 13.08 \end{bmatrix} \Omega \\
 \lambda_t &= 0.015 i_t + 0.691 \tan^{-1} \frac{i_t}{0.142} \text{ p.u.}, \quad R_{mt} = 83.839 \text{ k}\Omega, \quad \lambda_r = 0.31 i_r + 0.83 \tan^{-1} \frac{i_r}{0.91} \text{ p.u.}
 \end{aligned} \tag{4.1}$$

Figure 9: (a) Transient equivalent circuit of R - L coupled branches; (b) transient equivalent circuit of transmission lines.

Figure 10: Equivalent calculation network.

For the sake of convenience, Figure 7 is depicted as a single phase network taking matrix form, as shown in Figure 8. The R - L coupled branches and the transmission lines are further represented as their respective transient equivalent circuits, as shown in Figure 9. In the transient equivalent circuits, R_{RL} and $I_{RL}(t)$ are the equivalent resistance matrix and current source vector of the R - L coupled branches, and Z , $I_{ls}(t)$ and $I_{lr}(t)$ are the phase surge impedance matrix and historical current source vectors of the transmission lines, respectively. The special formulas for calculating these matrices and vectors have been derived in [5, 15]. By combining Figure 9 with Figure 8, an equivalent calculation network is given in Figure 10. With the terminals of the transformer and reactor magnetizing branches open-circuited in Figure 10, two Thevenin equivalent subnetworks can be found, and then the transient calculation can be performed by following the procedure stated above. The calculated voltage waveforms at the receiving end of transmission lines are shown in Figure 11, where the corresponding experimental waveforms obtained from the laboratory-scale model network are simultaneously given for comparison. It can be seen from Figure 11 that a better consistency appears between calculated and experimental results. In addition, the receiving end voltages are calculated by the traditional piecewise linear approach. The nonlinear saturation curve is simulated as piecewise linear inductances with 3 slopes. The calculated result shows that sudden jumps occur on the calculated voltage waveforms and make them unsmoothed, as illustrated in Figure 12. However, such a numerical error is not found on the voltage waveforms calculated by the proposed algorithm. The voltage peak values calculated

Figure 11: Calculated and experimental voltage waveforms.

by the proposed algorithm are closer to the experimental values than these by the piecewise linear approach.

5. Conclusions

An approach to modeling the magnetic saturation characteristics of magnetizing branches has been presented. It uses a continuous function to represent the saturation curves instead of the piecewise linearization and is capable of characterizing the saturation nonlinearity of practical ferromagnetic components. By implementing this approach into transient calculation, an efficient algorithm has been developed. The transient behavior of the magnetizing branches is described by a set of nonlinear differential equations, and the semiexplicit Runge-Kutta method is employed to solve these equations so that the iterative

Figure 12: Contrast voltage waveforms.

computations can be avoided. Then, the complete network solution can be obtained in terms of the solution to the magnetizing branches. The algorithm is useful in numerical simulation of the transients in the electric networks including ferromagnetic components. A better agreement is shown between calculated and experimental results, which verifies the validity of the algorithm.

Acknowledgments

This work is carried out by the financial assistance from National Natural Science Foundation of China under Award no. 509770026. The author acknowledges the support given by the foundation committee.

References

- [1] H. W. Dommel, "Nonlinear and time-varying elements in digital simulation of electromagnetic transients," *IEEE Transactions on Power Apparatus and Systems*, vol. 90, no. 6, pp. 2561–2567, 1971.
- [2] A. Narang and R. H. Brierley, "Topology based magnetic model for steady-state and transient studies for three-phase core type transformers," *IEEE Transactions on Power Systems*, vol. 9, no. 3, pp. 1337–1349, 1994.
- [3] A. Tokic, V. Madzarevic, and I. Uglesic, "Numerical calculations of three-phase transformer transients," *IEEE Transactions on Power Delivery*, vol. 20, no. 4, pp. 2493–2500, 2005.
- [4] H. W. Dommel, *EMTP Theory Book*, Microtran Power System Analysis Corporation, Vancouver, BC, Canada, 1992.
- [5] W. W. Han and F. L. Zhang, *Numerical Computation of Transient Overvoltages in Power Systems*, Science China Press, 1992.
- [6] A. Gaudreau, P. Picher, L. Bolduc, and A. Coutu, "No-load losses in transformer under overexcitation/inrush-current conditions: tests and a new model," *IEEE Transactions on Power Delivery*, vol. 17, no. 4, pp. 1009–1017, 2002.
- [7] O. Ozgonenel and G. Onbilgin, "Simulation of power transformers using state variables," *IEEE Power Engineering Review*, vol. 22, no. 10, pp. 48–50, 2002.
- [8] A. Rezaei-Zare, M. Sanaye-Pasand, H. Mohseni, S. Farhangi, and R. Iravani, "Analysis of ferroresonance modes in power transformers using Preisach-type hysteretic magnetizing inductance," *IEEE Transactions on Power Delivery*, vol. 22, no. 2, pp. 919–929, 2007.
- [9] D. A. Tziouvaras, P. McLaren, G. Alexander et al., "Mathematical models for current, voltage, and coupling capacitor voltage transformers," *IEEE Transactions on Power Delivery*, vol. 15, no. 1, pp. 62–72, 2000.
- [10] X. H. Xu and F. S. Zhu, *Numerical Solution of Stiff Ordinary differential Equations*, Wuhan University Press, Wuhan, China, 2001.
- [11] J. Z. Den, R. J. Ge, and X. Z. Chen, *Computational Mathematics*, Xianjiaotong University Press, Xi'an, China, 1996.
- [12] H. H. Rosenbrock, "Some general implicit processes for the numerical solution of differential equations," *The Computer Journal*, vol. 5, pp. 329–330, 1962/1963.
- [13] D. A. Calahan, "A stable, accurate method of numerical integration for nonlinear systems," *Proceedings of the IEEE*, vol. 56, no. 3, p. 744, 1968.
- [14] Y. Zhang and Z. Xiaoqing, "Modeling of magnetizing characteristics of ferromagnetic components in transient calculation," *Journal of Electric Power Systems*, vol. 20, no. 3, pp. 235–239, 2005.
- [15] X. Wang, X. Zhang, and D. Yang, "An efficient algorithm of transient responses on wind turbine towers struck by lightning," *COMPEL*, vol. 28, no. 2, pp. 372–384, 2009.